

**ADDENDUM #1**

Owner:  
Montana State University  
Facilities Management  
Owner Rep: Donny Beebe  
Project Manager, PDC

Architect:  
Architects Alaska, Incorporated  
347 S Ferguson Ave, Suite 3  
Bozeman, Montana 59718  
Project Architect: Thomas Brown

---

**NOTICE TO BIDDERS**

This Addendum is issued pursuant to the Instructions to Bidders. This Addendum serves to clarify, revise, and supersede information in the Contract Documents and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.

The Bidder shall acknowledge receipt of this Addendum on the Bid Form.

The Date for receipt of bids is unchanged.

---

**BIDDER QUESTIONS**

**Question 1      Are the double doors between Extruder Room 132A and Hall 133 fire rated?**

*Answer 1*      No.

**Question 2      Is the intent for the existing hardware (including closers and hinges) to be reused? Or is the new hardware preferable?**

*Answer 1*      If the existing hardware is salvageable and functions properly with the flipped orientation then reusing hardware is preferred.

**Question 2      What kind of hold-open hardware do you have in mind? (door stop, arm, etc.)**

*Answer 1*      If the existing hardware allows the doors to swing wider to the adjacent walls, then a wall mounted magnetic hold-open would be preferred for both doors.

---

**ATTACHMENTS**

NONE

\*\*\*END OF ADDENDUM\*\*\*